


C-144/244 REPLACEMENT PARTS



ID	Part No.	Description
1	See Replacement Stem Section	Stem Assembly, Contains: 1, 4, 10
2	300-1008	Valve Stem Cap
3	C-134KT-805	Handle and Screw Kit
4	C-134KT-802	Seat Washer Replacement Kit (00 Beveled)
5	C-134KT-803	Stem Packing Replacement Kit
6	310-1015	Valve Stem Cap for Loose Key
7	336-0043	Stem Packing Only
8	C-108KT-808	Oval Style Key on Lanyard
9	C-144KT-806	Universal Vacuum Breaker Replacement Kit
10	336-0002	Backflow Check Valve for C-144
	C-134KT-804	Handle to Loose Key Conversion Kit Contains: 5,6,8
	C-234KT-804	Loose Key to Handle Conversion Kit Contains: 2, 3, 5
	C-144KT-807	C-144 Overhaul Kit Contains: 3, 4, 5, 9, 10

*The C-144KT-806 Universal Vacuum Breaker Kit fits all current and past PRIER and Mansfield style residential hydrants.

REPLACEMENT STEMS



G Style Manufactured April 2013 - Present

Part No.	Style	Stem Length	Description
310-0063	G	3 5/16" OAL	Super Close Coupled Stem for C-144 Hydrant
P-231-12CC	G	4 7/16" OAL	Close Coupled Stem for C-144 Hydrant
P-231-1204	G	6 15/16" OAL	Stem for C-144 Series 4" Hydrant
P-231-1206	G	8 15/16" OAL	Stem for C-144 Series 6" Hydrant
P-231-1208	G	10 15/16" OAL	Stem for C-144 Series 8" Hydrant
P-231-1210	G	12 15/16" OAL	Stem for C-144 Series 10" Hydrant
P-231-1212	G	14 15/16" OAL	Stem for C-144 Series 12" Hydrant
P-231-1214	G	16 15/16" OAL	Stem for C-144 Series 14" Hydrant
P-231-1216	G	18 15/16" OAL	Stem for C-144 Series 16" Hydrant
P-231-1218	G	20 15/16" OAL	Stem for C-144 Series 18" Hydrant
P-231-1220	G	22 15/16" OAL	Stem for C-144 Series 20" Hydrant
P-231-1222	G	24 15/16" OAL	Stem for C-144 Series 22" Hydrant
P-231-1224	G	26 15/16" OAL	Stem for C-144 Series 24" Hydrant
P-231-12US	G	Up to 16 15/16" OAL	*Universal Replacement Stem for C-144 Hydrant

**For stems manufactured before 2013, see C-144 Series retired style spec sheet at PRIER.com. PRIER universal stems are replacement stems for any size from 4" to 14." The P-231-12US Universal Stem requires cutting the rod to proper length and soldering the brass stem end to the rod as directed in instructions.

4515 E. 139th Street Grandview, MO 64030 | (800) 362-9055 | PRIER.com

*Per ASSE 1019 Code, do not leave on for more than 12 continuous hours.

C-144-X

OLD STYLE
Manufactured 1972-April 2013



4515 East 139th Street
 Grandview, MO 64030
 (800) 362-9055
 Fax (800) 362-1463
 www.PRIER.com


C-144/244 Series Freezeless Wall Hydrant



- Freezeless
- Anti-Siphon
- Backflow Check Valve



Replacement Parts and Stems



ID	Part No.	Description
1	See Below	Stem Assembly, Contains: 1, 4, 10
2	300-1008	Valve Stem Cap
3	C-134KT-805	Oval Handle and Screw Kit
4	C-134KT-802	Seat Washer Kit (00 Beveled)
5	C-134KT-803	Stem Packing Replacement Kit
6	310-1015	Valve Stem Cap for Loose Key
7	336-0043	Stem Packing Only
8	C-108KT-808	Oval Style Key on Lanyard
9	C-144KT-806	Vacuum Breaker Replacement Kit
10	336-0002	Backflow Check Valve for C-144
	C-134KT-804	Loose Key Conversion Kit Contains: 5,6,8
	C-144KT-807	C-144 Overhaul Kit Contains: 3, 4, 5, 9, 10

"A" Dimension 1/2"



E Style Manufactured 1972 - April 2013

Part No.	Style	Stem Length	Description
P-231-02CC	E	5 1/8" OAL	Close Coupled Stem for C-144 Hydrant
P-231-0204	E	7 5/8" OAL	Stem for C-144 Hydrant
P-231-0206	E	9 5/8" OAL	Stem for C-144 Hydrant
P-231-0208	E	11 5/8" OAL	Stem for C-144 Hydrant
P-231-0210	E	13 5/8" OAL	Stem for C-144 Hydrant
P-231-0212	E	15 5/8" OAL	Stem for C-144 Hydrant
P-231-0214	E	17 5/8" OAL	Stem for C-144 Hydrant
P-231-0216	E	19 5/8" OAL	Stem for C-144 Hydrant
P-231-0218	E	21 5/8" OAL	Stem for C-144 Hydrant
P-231-0220	E	23 5/8" OAL	Stem for C-144 Hydrant
P-231-0222	E	25 5/8" OAL	Stem for C-144 Hydrant
P-231-0224	E	27 5/8" OAL	Stem for C-144 Hydrant
P-231-02US	E	Up to 17 5/8" OAL	*Universal Replacement Stem for C-144 Hydrant

PRIER Universal Stems are replacement stems for any size from Close Coupled to 14". They require cutting the rod to proper length and soldering the brass stem end to the rod as directed in instructions.